

Have you upgraded your plant to a new disinfection system? If so, what were your biggest challenges?



Gilnei Campani • 3rd+
Eng. Químico na Di Acqua Engenharia Ltda

1w ***

The main challenges are related to the change of work routine due to the new technologies used, which usually require different routines and different modes of operation and maintenance.



Ghazi ALMANI • 2nd
Sales Director & Marketing Consultant. MENA Filtration (R.O, U.F. & W...

1w (edited) ***

Had been involved in the transition in Dubai as well in Abu Dhabi and Latley in Saudi Arabia and soon in other countries. There was no increase in maintenance cost. It was even a bit safer and better performances. Some went with chlorine dioxide and others in on site generation and expect new technologies in the very near future. Safety, Effectiveness for the type of treated water and Influent, ease to operate and control as well availability and handling of raw materials. Have to look at it from all factors.



Robert Poling Jr, CPWM • 2nd
Free Agent

1w ***

Nice tablet system (Constant Chlor) but pumps were undersized along with miscalculating chase water feed pressure. Feed piping was also made a lot more complicated than needed.



David Kudray • 2nd
Lead WasteWater Operator at Department of Defense

4d ***

We went to Ultra Violet from Cl 2 gas. Less dangerous for operators and no harm to environment